

MINUTES OF APRIL 15, 2015 POLLUTION CONTROL COMMITTEE (DHWWTf) MEETING

Present: Craig Olson, Paul Pendleton, Grayson Hartley, Yvette Reid, David Pendleton
Also: Isaiah Bean and Andy Bryan of Ted Berry Co., Mark Craig and Town Manager Janet Anderson
Chair Olson opened the meeting at 10:10am.

Minutes:

Upon a motion by D. Pendleton and seconded by G. Hartley the Minutes of the September 4, 2014 Meeting were approved.

VOTE: All in favor

Update on 2014 Sanitary Sewer Rehabilitation Project:

Isaiah Bean and Andy Bryant came today to update us on last fall's project and what could come next.

They performed 20 fiberglass repair spots. They discovered two manholes. The first new one (#5) by Paul Pendleton's is in bad condition with roots and water infiltration - ***we will have Peter Coombs replace this in the fall.***

This project was the biggest step in the rehab project. Every 2-5 years we could follow-up and check on the levels 1 & 2.

Lots of laterals have water coming in even though no one was living in the home at the time. Possible roof drains tied in? Need to determine.

The second newly discovered manhole (#15) is located below the old bus barn and has not been capped off. ***We will have Mark or Peter Coombs look at this one this fall.***

"DE" have Ted Berry push camera in here to find to confirm 2 laterals – **replace.**

RE Checking out Laterals:

1. Sump pump
2. Roof drains
3. Leaking t-valves

On Derby Road, in front of the old P.A. house, an old dried out-well was discovered.

RE: Future New Breaks into the System:

David suggests we have a plan for new homeowners joining the system. They must use a PVC Y-pipe and then inspected by the Town.

- **Holding tanks should be pumped out and cleaned.**

Draft FY16 Budget was handed out.

NEXT MEETING: June 10th at 10am to set 2015 sewer rate.

Meeting adjourned at 10:55am.