

Date: 01/28/2016

TOWN OF ISLESBORO
P.O BOX 76
ISLESBORO, Maine 04848

RE: Application number A-2015-1401
Licensee reference number: ISLESBORO05

Dear Cristin Turner:

Enclosed, please find Form 4, Authorization for Pole Make-Ready Work.

Please sign this form and return it with your check made payable to **FairPoint Communications** in the amount of **\$20,185.50**. This amount due is for the Make-Ready Work associated with the application number referenced above in the vicinity of PRIVATE RD, FERRY RD, DUFFERS LANE, MCCORISON LANE, GOOSEBERRY POINT, MILL CREEK RD, TEHAN LANE, GOLF CLUB RD, DUNN LANE, STEVENS DR., Islesboro, ME.

Please note: If payment is not received by 02/27/2016 the application will be canceled and you will need to reapply.

Please call 1-866-774-5228 to speak with a License Administration Associate should you have any questions.

Please submit payment to:

**Fairpoint Communications
License Administration Group
5 Davis Farm Rd
Portland, ME 04103**

Sincerely,

Cathleen Adams
License Administration

Attachments

AUTHORIZATION FOR POLE MAKE-READY WORKLicensee: **Town of Islesboro**

Field survey work associated with your License Application No. **Islesboro 05** dated **November 17, 2015**
 for attachments to poles in the municipality of **Islesboro**, State of **ME** has been completed.
 Following is a summary of the make-ready charges which will apply:

TASK #	QUANTITY	UNIT COST	TOTAL COST
7A	5	\$227.70	\$1,138.50
7B	4	\$110.00	\$440.00
10A	7	\$218.90	\$1,532.30
10B	2	\$102.30	\$204.60
11A	27	\$258.50	\$6,979.50
11B	16	\$85.80	\$1,372.80
14A	1	\$253.00	\$253.00
Work Order Preparation			\$165.00
Additional charge Sheet 2			\$8,099.80

Attached as requested, is an itemized unit cost (Form 3) of required make-ready work and associated charges. If you wish us to complete the required make-ready work, please sign this copy below and return with an advance payment in the amount of **\$20,185.50**

Licensors Name (Print) **FAIRPOINT**
 Signature ***William R Redman***
 Title **Outside Plant Engineer**
 Address **5 Davis Farm Rd
Portland, ME 04103**
 Telephone Number **207-951-6949**
 Date **January 28, 2016**

The replacements and rearrangements included in Pole Attachment License Application No. **Islesboro 05** are authorized and the costs therefore will be paid to Licensors in accordance with Appendix I to Pole Attachment License Agreement. My check is attached.

Licensee's Name (Print) _____

Signature _____

Telephone Number _____

Title _____

Date _____

TASK #	QUANTITY	UNIT COST	TOTAL COST
19A	20	\$157.30	\$3,146.00
19B	6	\$35.20	\$211.20
20A	3	\$156.20	\$468.60
20B	7	\$35.20	\$246.40
21A	5	\$152.90	\$764.50
25A	5	\$210.10	\$1,050.50
25B	4	\$93.50	\$374.00
17A	2	\$157.30	\$314.60
26	4	\$256.00	\$1,024.00
30	1	\$500.00	\$500.00

TASK #30 Ferry Tolls for crews and equipment

FORM 3 - FAIRPOINT ITEMIZED POLE MAKE-READY WORK CHARGES

Appendix IV Form 3

FIELD SURVEY / MAKE READY WORK FORM																	
RCE to Complete - Total Poles Surveyed			200		Total Poles Requiring Make Ready			Fairpoint		51 Others		28					
Surveyors:			Survey Date:		12/07/15		Survey Order #		MEA20151522APP								
Fairpoint Bill Redman			Munic:		Islesboro		State:		Maine		Exch Code:		7283 Munic Code: 7283901				
Licensee			Licensee Name:		Town of Islesboro		Licensee Application #		Islesboro 05								
Elco Elmer Plummer			Elco Name:		Central Maine Power		LAG Application #		A-2015-1522		days						
Location		Pole #		Attach		Ownership		Description of Work		FP		Others		Tasks		Attach location see notes	
Tel Rte / Street Name	Tel	El	F/C PS	J.O. Tel	J.U. El	S.O. Tel	S.O. El										
RP940 / Off Ferry Rd P.8[8]	2	8.2	F		X			No make ready required. Guying required.									*
RP940 / Off Ferry Rd P.8[8]	3 (8-3)	8.3	F		X			No make ready required.									*
RP940 / Off Ferry Rd P.8[8]	4	8.4	F		X			Tel lower 1 d/w 12"		X					19A		*
RP940 / Off Ferry Rd P.8[8]	5	8.5	F		X			Tel lower 1 d/w 12". Guying required.		X					19A		*
Rte 3 / Ferry Rd	9	9	F		X			Tel lower 2 strands(2 ca) 12"		X					11A,11B		*
Rte 3 / Ferry Rd	10	10	F		X			CMP pull slack neutral P.10-11. No tel make ready required.			X						*
Rte 3 / Ferry Rd	11	11	F		X			No make ready required. Guying required.									*
Rte 3 / Ferry Rd	12	12	F		X			No make ready required.									*
Rte 3 / Ferry Rd	13	13	F		X			No make ready required.									*
Rte 3 / Ferry Rd	13-1	13.01	F		X			Tel lower 3 crw, 1 d/w, 1 wire term 24". Guying required.		X					20A,(2)20B,19B,21A		*
Rte 3 / Ferry Rd	13-2	13.02	F		X			CMP raise 2 services 12" & shorten taps. Tel lower 1 d/w 12". Guying required.		X	X				19A		*
Rte 34 / McCorison Ln off Rte 3 P.13[13]	1	13.1						No pole found.									*
Rte 34 / McCorison Ln	2	13.2	F		X			CMP rpl 35'/40' & anchor. Tel transfer 1 strand(1 ca), rpl 1 PA guy. Guying required.		X	X				7A,11A,25A		*
Rte 34 / McCorison Ln	3	13.3	F		X			CMP rpl 35'/40' & anchor. Tel transfer 1 strand(1 ca), rpl 1 PA guy. Guying required.		X	X				7A,11A,25A		*

Location			Pole #	Attach	Ownership									Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.		Description of Work	FP	Others	Tasks	
				Tel	El	Tel	El	Tel	El					
Rte 34 / McCorison Ln	4	13.4	F				X			No make ready required. Guying required.				*
Rte 34 / McCorison Ln	4-1	13.41	F				X			No make ready required. Guying required.				*
Rte 34 / McCorison Ln	NT	13.5	F						X	No Tel on pole. No make ready required.				*
Rte 3 / Ferry Rd	14	14	F				X			CMP raise service to neutral & shorten taps. No tel make ready required.	X			*
Rte 3 / Ferry Rd	14-1	14.1	F				X			No make ready required.				*
Rte 3 / Ferry Rd	NT	14.2								CMP transformer pad.				*
Rte 3 / Ferry Rd	15	15	F				X			No make ready required. Guying required.				*
Rte 3 / Ferry Rd	16	16	F				X			No make ready required. Guying required.				*
Rte 3 / Ferry Rd	NT	16S							X	No Tel on pole. No make ready required. Guying required.				*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-1	16.1	F				X			CMP rpl 35'/40'. Tel transfer 1 mdw, 5 d/w, 1 wire term. NO CHARGE. Noncompliant clearance 13'3" driveway.	X	X		*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-11	16.11	F				X			No make ready required. Guying required.				*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-12	16.12	F				X			Tel lower 2 d/w 12" .	X		19A,19B	*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-2	16.2	F				X			CMP rpl 35'/40'. Tel transfer 1 mdw, 6 d/w, 1 wire term, 1 bsw. NO CHARGE. Noncompliant clearance, Tel 18" from URD weatherhead.	X	X		*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-21	16.21	F				X			No make ready required. Guying required.				*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	16-3	16.3	F				X			No make ready required. Guying required.				*
Rte 3 / Gooseberry Point off P.16[16] Ferry Rd	NT	16.4								CMP transformer pad.				*
Rte 3 / Ferry Rd	17	17	F				X			No make ready required. Guying required.				*
Rte 3 / Ferry Rd	17-1	17.1	F				X			CMP rpl 35'/40'. Tel transfer 1 mdw, 8 d/w, 1 wire term. NO CHARGE. Noncompliant clearance, 24" from neutral.	X	X		*

Location			Pole #	Attach		Ownership						Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.								
				Tel	El	Tel	El	Tel	El	Tel	El					
Rte 3 / Ferry Rd	17 1/2-1	17.1H	F					X				No make ready required.				*
Rte 3 / Ferry Rd	17-11	17.11	F					X				Tel lower 3 d/w, 1 wire term 12"	X		19A,(2)19B,21A	*
Rte 3 / Ferry Rd	17-2	17.2	F					X				No make ready required. Guying required.				*
Rte 3 / Ferry Rd	18	18	F					X				No make ready required.				*
Rte 3 / Ferry Rd	NT	18S									X	No Tel on pole. No make ready required. Guying required.				*
Rte 3 / Ferry Rd	18-1	18.1	F					X				No make ready required. Guying required.				*
Rte 3 / Ferry Rd	19	19	F					X				CMP rpl 35'/45'. Tel transfer 2 strands(2 ca), 1 d/w . Guying required.	X	X	11A,11B,17A	*
Rte 3 / Ferry Rd	NT	19H										No pole found.				*
Rte 3 / Ferry Rd	19-1	19.1	F					X				No make ready required.				*
Rte 3 / Ferry Rd	20	25	F					X				No make ready required.				*
Rte 3 / Ferry Rd	21	26	F					X				No make ready required. Guying required.				*
RP952 / off Ferry Rd P.21	1	26.1	F					X				No make ready required.				*
RP952 / off Ferry Rd P.21	2	26.2	F					X				Tel lower 1 d/w 12". Guying required.	X		19A	*
Rte 3 / Ferry Rd	22	27	F					X				No make ready required. Guying required.				*
Rte 3 / Ferry Rd	23	28	F					X				No make ready required. Guying required.				*
Rte 3 / Ferry Rd	24	29	F					X				No make ready required.				*
Rte 3 / Ferry Rd	25	30	F					X				No make ready required.				*
Rte 3 / Ferry Rd	26	31	F					X				No make ready required.				*
Rte 3 / Ferry Rd	26PB	31PB						X				No make ready required.				*
Rte 3 / Ferry Rd	27	32	F					X				No make ready required.				*

Location			Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.	J.U.	S.O.	J.O.		J.U.		S.O.								
Rte 3 / Ferry Rd	27PB	32PB															*		
Rte 3 / Ferry Rd	28	33	F													11A	*		
Rte 3 / Ferry Rd	NT	33.1															*		
Rte 3 / Ferry Rd	29	34	F													11A	*		
Rte 3 / Ferry Rd	29PB	34PB															*		
Rte 3 / Ferry Rd	30	35	F														*		
Rte 3 / Ferry Rd	30PB	35PB															*		
Rte 3 / Ferry Rd	31	36	F														*		
Rte 3 / Ferry Rd	32	37	F														*		
Rte 3 / Ferry Rd	NT	37H															*		
Rte 3 / Ferry Rd @ Ferry Terminal	32-1	38	F													19A	*		
Rte 3 / Ferry Rd @ Ferry Terminal	32-2	39	F														*		
Rte 3 / Ferry Rd @ Ferry Terminal	NT	40	F														*		
Rte 4 / Mill Creek Rd	1	26	F													X	*		
Rte 4 / Mill Creek Rd	1-1	26.1	F													X	*		
Rte 4 / Mill Creek Rd	2	25	F														*		
Rte 4 / Mill Creek Rd	3	24	F													X	10A,10B,11A,11B		
Rte 4 / Mill Creek Rd	4	23	F														*		
Rte 4 / Mill Creek Rd	5	22	F													X	11A		
Rte 4 / Mill Creek Rd	5-1	22.1	F														*		

Location		Pole #	Attach	Ownership						Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 4 / Mill Creek Rd	7	20	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	7-1	20.1	F				X			Tel lower 2 d/w, 1 wire term 12". Guying required.	X			19A,19B,21A	*
Rte 4 / Mill Creek Rd	7S	20S					X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	8	19	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	9	18	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	10	17	F				X			Tel lower 2 strands(3 ca), 1 PA guy 12". Guying required.	X			10A,11A,11B	*
Rte 4 / Mill Creek Rd	11	16	F				X			Tel lower 2 strands(3 ca) 12".	X			11A,11B	*
Rte 4 / Mill Creek Rd	12	15	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	13	14	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	14	12	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	15	11	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	16	10	F				X			CMP rpl 35'/45'. Tel transfer 3 strands(4 ca), rpl 1 PA guy . Guying required.	X	X		7A,11A,(2)11B,25A	*
Rte 4 / Mill Creek Rd	NT	10.1	F						X	No Tel on pole. No make ready required.					*
Rte 41 / Tehan Ln off Rte 4 P.16	1	1	F				X			No make ready required. Guying required.					*
Rte 41 / Tehan Ln	1 1/2	1H	F				X			No make ready required.					*
Rte 41 / Tehan Ln	2	2	F				X			No make ready required.					*
Rte 41 / Tehan Ln	3	3	F				X			No make ready required.					*
Rte 41 / Tehan Ln	4	4	F				X			No make ready required. Guying required.					*
Rte 41 / Tehan Ln	4-1	4.1	F				X			No make ready required.					*
Rte 41 / Tehan Ln	4-2	4.2	F				X			No make ready required. Guying required.					*

Location		Pole #	Attach	Ownership						Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 41 / Tehan Ln	5	5	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	17	9	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	18	8	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	18-1	8.1	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	18-2	8.2	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	19	7	F				X			CMP rpl 35'/45'. Tel transfer 2 strands(3 ca), 1 d/w, 1 PP guy.	X	X	10A,11A,11B,17A		*
Rte 4 / Mill Creek Rd	19S	7.1	F				X			Tel lower 1 d/w, 1 wire term 12" .	X		19A,21A		*
Rte 4 / Mill Creek Rd	20	6	F				X			No make ready required.					*
Rte 4 / Mill Creek Rd	20-1	6.1	F				X			CMP straighten pole & pull slack secondary. Tel lower 2 d/w 12" .	X	X	19A,19B		*
Rte 4 / Mill Creek Rd	21	5	F				X			Tel lower 2 strands(3 ca), 1 repeater stub. CMP raise secondary 12" .	X	X	11A,(2)11B		*
Rte 4 / Mill Creek Rd	22	4	F				X			Tel lower top strand(1 ca) 6" .	X		11A		*
Rte 4 / Mill Creek Rd	23	2	F				X			Tel lower top strand(1 ca) 6" .	X		11A		*
Rte 4 / Mill Creek Rd	NT	2.1	F						X	No Tel on pole. No make ready required.					*
Rte 4 / Mill Creek Rd	24	1	F				X			No make ready required. Guying required.					*
Rte 4 / Mill Creek Rd	25	20	F				X			CMP rpl 40'/50' & 2 anchors. Tel transfer 4 strands(6 ca), 1 term, rpl 4 PA guys. Guying required.	X	X	7A,(3)7B,11A,(3)11B, 14A,25A,(3)25B		*
Rte 941 / Golf Club Rd off Rte 4 P.25 Mill Creek Rd	1	1	F				X			Tel lower 1 strand(1 ca), 1 PP guy 12" .	X		10A,11A		*
Rte 941 / Golf Club Rd	2	2	F				X			CMP rpl 35'/45'. Tel transfer 1 strand(2 ca), 1 d/w. NO CHARGE. Noncompliant clearance Tel 15'2" road, cable tied to tree.	X	X			*

Location			Pole #		Attach		Ownership						Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.	J.U.	S.O.											
				Tel	El	Tel	El	Tel	El								
Rte 941 / Golf Club Rd	3	3	F				X					Tel transfer to new pole. Work on another authority. CMP has transferred. Tel transfer 1 strand(1 ca), 1 PA guy. Guying required. NO CHARGE.	X			*	
Rte 941 / Golf Club Rd	4	4	F				X					CMP raise 1 service 12" & shorten taps. No tel make ready required. Guying required.	X			*	
Rte 941 / Golf Club Rd	5	5	F				X					No make ready required. Guying required.				*	
Rte 941 / Golf Club Rd	5 1/2	6	F				X					No make ready required. Guying required.				*	
Rte 9411 / Golf Club Rd	1	6.1	F				X					No make ready required. Guying required.				*	
Rte 9411 / Golf Club Rd	2	6.2	F				X					No make ready required. Guying required.				*	
Rte 9411 / Golf Club Rd	NT	6.22										CMP transformer pad.				*	
Rte 9411 / Golf Club Rd	2-1	6.3	F				X					No make ready required.				*	
Rte 9411 / Golf Club Rd	2-2	6.4	F				X					Tel lower 1 crdw, 2 crw 12" . Guying required.	X		20A,(2)20B	*	
Rte 941 / Golf Club Rd	6	8	F				X					No make ready required.				*	
Rte 941 / Golf Club Rd	7	9	F				X					CMP pull slack primary & neutral. Tel retension 3 crw, 1 d/w. NO CHARGE. Wires very slack. Guying required.	X	X		*	
Rte 941 / Golf Club Rd	7-1	9.1	F				X					No make ready required.				*	
Rte 941 / Golf Club Rd	7-2	9.2	F				X					No make ready required.				*	
Rte 941 / Golf Club Rd	7-3	9.3	F				X					No make ready required. Guying required.				*	
Rte 941 / Golf Club Rd	8	10	F				X					No make ready required. Guying required.				*	
Rte 941 / Golf Club Rd	NT	10.1										CMP transformer pad.				*	
Rte 941 / Golf Club Rd	NT	10.2										CMP transformer pad.				*	
Rte 4 / Mill Creek Rd	26	19	F				X					CMP rpl 35'/45' & anchor. Tel transfer 2 strands(3 ca), rpl 2 PA guy. Guying required.	X	X	7A,7B,11A,11B,25A, 25B	*	

Location			Pole #	Attach	Ownership						Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 4 / Mill Creek Rd	27	18	F				X						No make ready required.		*
Rte 4 / Mill Creek Rd	28	17	F				X						No make ready required.		*
Rte 4 / Mill Creek Rd	29	16	F				X						No make ready required. Guying required.		*
Rte 4 / Mill Creek Rd	29 1/2	15	F				X						No make ready required. Guying required.		*
Rte 4 / Mill Creek Rd	30	14	F				X						No make ready required.		*
Rte 4 / Mill Creek Rd	31	12	F				X						No make ready required.		*
Rte 4 / Mill Creek Rd	32	11	F				X				X		Tel lower 2 strands(3 ca) 12".	11A,11B	*
Rte 4 / Mill Creek Rd	33	9	F				X				X	X	CMP rpl 35'/40'. Tel trnsfer 2 strands(3 ca), 2 d/w, 1 mdw. NO CHARGE. Noncompliant clearance, Tel 24" from neutral.		*
Rte 4 / Mill Creek Rd	33-1	9.1	F				X					X	CMP rpl 30'/40'. Tel transfer 2 d/w, 1 wire term. NO CHARGE. Noncompliant clearance, CMP 12'4", Tel 14' over driveway.		*
Rte 4 / Mill Creek Rd	33-2	9.2	F				X				X	X	Tel lower 1 d/w, 1 wire term 12". Guying required.	19A,21A	*
Rte 4 / Mill Creek Rd	33 1/2	7	F				X						No make ready required. Guying required.		*
Rte 4 / off Mill Creek Rd	33 1/2-1	1	F				X						No make ready required.		*
Rte 4 / off Mill Creek Rd	33 1/2-2	2	F				X						No make ready required. Guying required.		*
Rte 4 / off Mill Creek Rd	33 1/2-3	3	F				X						No make ready required. Guying required.		*
Rte 4 / off Mill Creek Rd	33 1/2-4	4	F				X						No make ready required. Guying required.		*
Rte 4 / Mill Creek Rd	34	6	F				X					X	Tel lower 2 strands(3 ca) 12".	11A,11B	*
Rte 4 / Mill Creek Rd	34 1/2	5H	F				X						No make ready required. Guying required.		*
Rte 4 / Mill Creek Rd	34 1/2-1	5H.1	F				X					X	Tel lower 1 d/w 12".	19A	*

Location			Pole #	Attach		Ownership						Tasks		Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.		Description of Work	FP	Others		
				Tel	El	Tel	El	Tel	El					
Rte 4 / Mill Creek Rd	35	5	F					X		No make ready required.				*
Rte 4 / Mill Creek Rd	36	4	F					X		No make ready required.				*
Rte 4 / Mill Creek Rd	37	3	F					X		No make ready required.				*
Rte 4 / Mill Creek Rd	37-1	3.1	F					X		Tel lower 1 mdw 12". Guying required.	X		19A	*
Rte 4 / Mill Creek Rd	38	2	F					X		CMP raise 1 service 12" & shorten taps. No tel make ready required.		X		*
Rte 4 / Mill Creek Rd	39	1	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	564	234	F					X		No make ready required.				*
TS264 / Main Rd	565	233	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	565S	233S						X		Tel lower 1 PP guy, 1 PA guy, 1 d/w 12". Guying required.	X		10A,10B,19A	*
TS264 / Main Rd	566	232	F					X		Tel lower 1 PP guy to strand, place eye nut. Lower 1 d/w 12". Guying required.	X		11A,19A	*
TS264 / Main Rd	566D	232.1	F					X		CMP raise secondary 12". Tel lower 1 PP guy, 1 d/w 12". Guying required.	X	X	10A,19A	*
TS264 / Main Rd	566DD	232.2	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	567	231	F					X		No make ready required.				*
TS264 / Main Rd	568	230	F					X		Tel lower 1 strand(2 ca), 1 d/w, 1 PA guy 12". CMP raise 1 service 24" & shorten taps. Guying required.	X	X	10A,11A,19A	*
TS264 / Main Rd	569	229	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	570	228	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	571	227	F					X		No make ready required. Guying required.				*
TS264 / Main Rd	571-1	227.1	F					X		Tel lower 1 d/w 12". Guying required.	X		19A	*
Rte 906 / Dunn Ln off TS264 P.571	1	1	F					X		No make ready required.				*

Location		Pole #		Attach		Ownership						Tasks		Attach location see notes	
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.		Description of Work	FP	Others	Tasks		
				Tel	El	Tel	El	Tel	El						
Rte 906 / Dunn Ln	1-1	1.1	F				X			Tel lower 1 d/w 12". Guying required.	X		19A		*
Rte 906 / Dunn Ln	1 1/2	1H	F				X			No make ready required.					*
Rte 906 / Dunn Ln	2	2	F				X			Tel lower 3 crw, 1 d/w. Guying required.	X		19A,(3)20B		*
Rte 906 / Dunn Ln	2-1	2.1	F				X			No make ready required. Guying required.					*
Rte 906 / Dunn Ln	NT	2S								No pole found.					*
Rte 906 / Dunn Ln	3	3	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	572	226	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	573 (574)	225	F				X			No make ready required.					*
TS264 / Main Rd	574	224	F				X			No make ready required.					*
TS264 / Main Rd	575	223	F				X			No make ready required.					*
TS264 / Main Rd	576	222	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	576S	222S					X			No make ready required. Guying required.					*
TS264 / Main Rd	577	221	F				X			CMP shorten service taps. No tel make ready required.		X			*
TS264 / Main Rd	578	219	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	578S	219S					X			No make ready required. Guying required.					*
TS264 / Main Rd	579	218	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	579S	218S					X			No make ready required. Guying required.					*
TS264 / Main Rd	580	217	F				X			No make ready required.					*
TS264 / Main Rd	581	216	F				X			No make ready required. Guying required.					*
TS264 / Main Rd	581S	216S					X			No make ready required. Guying required.					*

Location		Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.										
				Tel	El	Tel	El	Tel	El	Tel	El							
TS264 / Main Rd	582	214	F					X						No make ready required.			*	
TS264 / Main Rd	583	213	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	584	212	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	584-1	212.1	F					X						No make ready required.			*	
TS264 / Main Rd	584-2	212.2	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	585	211	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	585 1/2	210	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	586	209	F					X						No make ready required.			*	
TS264 / Main Rd	589	207	F					X						No make ready required.			*	
TS264 / Main Rd	NT	207.1												CMP transformer pad.			*	
TS264 / Main Rd	591	205	F					X						No make ready required.			*	
TS264 / Main Rd	593	203	F					X						No make ready required.			*	
TS264 / Main Rd	594	202	F					X						No make ready required.			*	
TS264 / Main Rd	595	201	F					X						CMP raise space tag 12". Tel lower top crdw 12".	X	X 20A	*	
TS264 / Main Rd	595-1	201.1	F					X						No make ready required. Guying required.			*	
TS264 / Main Rd	595-2	201.11	F					X						No make ready required. Guying required.			*	
Rte 99 / Bounty Cove Rd (Stevens Drive) off TS264 P.595	1	1	F					X						No make ready required.			*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	2	2	F					X						No make ready required.			*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	3	3	F					X						No make ready required.			*	

Location		Pole #		Attach		Ownership						Tasks		Attach location see notes	
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.		Description of Work	FP	Others	Tasks	Attach location see notes	
				Tel	El	Tel	El	Tel	El						
Rte 99 / Bounty Cove Rd (Stevens Drive)	4	4	F				X			No make ready required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	5	5	F				X			No make ready required. Guying required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	6	6	F				X			No make ready required. Guying required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	7	7	F				X			No make ready required. Guying required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	8	8	F				X			No make ready required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	9	9	F				X			No make ready required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	10	10	F				X			No make ready required. Guying required.				*	
Rte 99 / Bounty Cove Rd (Stevens Drive)	NT	10.1								Customer owned meter pole.				*	
Totals				0	0	0	193	0	6		51	28			

Notes:

* Attach no closer than 40" below power attachment and 12" above telephone attachment.