

Date: 01/28/2016

TOWN OF ISLESBORO
P.O BOX 76
ISLESBORO, Maine 04848

RE: Application number A-2015-1397
Licensee reference number: ISLESBORO02

Dear Cristin Turner:

Enclosed, please find Form 4, Authorization for Pole Make-Ready Work.

Please sign this form and return it with your check made payable to **FairPoint Communications** in the amount of **\$12,288.90**. This amount due is for the Make-Ready Work associated with the application number referenced above in the vicinity of SHIPYARD POINT RD, PENDLETON POINT RD, TARRATINE CLUB RD, EAST SHORE RD, MERRILL FARM RD, HATCH LANE, PIERCE RD, BOARDMAN RD, GILLKEY LANE, DECKER RD, BABBIDGE RD, COLONY RD, WEST SHORE RD, LONG LEDGE DR, , Islesboro, ME.

Please note: If payment is not received by 02/27/2016 the application will be canceled and you will need to reapply.

Please call 1-866-774-5228 to speak with a License Administration Associate should you have any questions.

Please submit payment to:

**Fairpoint Communications
License Administration Group
5 Davis Farm Rd
Portland, ME 04103**

Sincerely,

Cathleen Adams
License Administration

Attachments

AUTHORIZATION FOR POLE MAKE-READY WORKLicensee: **Town of Islesboro**

Field survey work associated with your License Application No. **Islesboro 02** dated **November 17, 2015**
 for attachments to poles in the municipality of **Islesboro**, State of **ME** has been completed.
 Following is a summary of the make-ready charges which will apply:

TASK #	QUANTITY	UNIT COST	TOTAL COST
7A	3	\$227.70	\$683.10
10A	6	\$218.90	\$1,313.40
10B	1	\$102.30	\$102.30
11A	12	\$258.50	\$3,102.00
11B	3	\$85.80	\$257.40
14A	1	\$253.00	\$253.00
19A	22	\$157.30	\$3,460.60
Work Order Preparation			\$165.00
Additional charge Sheet 2			\$2,794.80

Attached as requested, is an itemized unit cost (Form 3) of required make-ready work and associated charges. If you wish us to complete the required make-ready work, please sign this copy below and return with an advance payment in the amount of **\$12,288.90**

Licensors Name (Print) **FAIRPOINT**
 Signature ***William R Redman***
 Title **Outside Plant Engineer**
 Address **5 Davis Farm Rd
Portland, ME 04103**
 Telephone Number **207-951-6949**
 Date **January 26, 2016**

The replacements and rearrangements included in Pole Attachment License Application No. **Islesboro 02** are authorized and the costs therefore will be paid to Licensors in accordance with Appendix I to Pole Attachment License Agreement. My check is attached.

Licensee's Name (Print) _____

Signature _____

Telephone Number _____

Title _____

Date _____

TASK #	QUANTITY	UNIT COST	TOTAL COST
19B	8	\$35.20	\$281.60
20A	1	\$156.20	\$156.20
21A	3	\$152.90	\$458.70
25A	3	\$210.10	\$630.30
26	3	\$256.00	\$768.00
30	1	\$500.00	\$500.00
17A	1	\$157.30	\$157.30

TASK #30 Ferry tolls for crews and equipment

FORM 3 - FAIRPOINT ITEMIZED POLE MAKE-READY WORK CHARGES

Appendix IV Form 3

FIELD SURVEY / MAKE READY WORK FORM																	
RCE to Complete - Total Poles Surveyed		200		Total Poles Requiring Make Ready		Fairpoint		34		Others		18					
Surveyors:		Survey Date:		11/10/15		Survey Order #		MEA20151397APP		Exch Code:		7283					
Fairpoint Bill Redman		Munic:		Islesboro		State:		Maine		Licensee Application #		Islesboro 02					
Licensee		Elco Elmer Plummer		Elco Name:		Central Maine Power		Elco Name:		A-2015-1397		days					
Location		Pole #		Attach		Ownership		Description of Work		FP		Others		Tasks		Attach location see notes	
Tel Rte / Street Name	Tel	El	F/C PS	J.O. Tel	J.O. El	J.U. Tel	J.U. El	S.O. Tel	S.O. El	Description of Work		FP	Others	Tasks	Attach location see notes		
Rte 53 / Shipyard Point Rd	16	16	F			X				Tel lower top strand(1 ca) 12".		X		11A	*		
Rte 53 / Shipyard Point Rd	17	17	F			X				Tel lower 1 strand(1 ca), 1 riser cable, 1 PA guy 12". Guying required.		X		10A,11A,11B	*		
Rte 4 / Pendleton Point Rd	115	377	F			X				No make ready required.					*		
Rte 4 / Pendleton Point Rd	114	376	F			X				No make ready required.					*		
Rte 4 / Pendleton Point Rd	113	375	F			X				No make ready required. Guying required.					*		
Rte 4 / Pendleton Point Rd	112	374	F			X				No make ready required. Guying required.					*		
Rte 4 / Pendleton Point Rd	111	373	F			X				No make ready required.					*		
Rte 4 / Pendleton Point Rd	110	372	F			X				No make ready required.					*		
Rte 4 / Pendleton Point Rd	109	371	F			X				No make ready required.					*		
Rte 4 / Pendleton Point Rd	108	370	F			X				No make ready required. Guying required.					*		
Rte 52 / Tarratine Club Rd off Rte 4 P.108 Pendleton Pt Rd	1	1	F			X				No make ready required.					*		
Rte 52 / Tarratine Club Rd	2	2	F			X				No make ready required. Guying required.					*		
Rte 52 / Tarratine Club Rd	3	3	F			X				No make ready required. Guying required.					*		
Rte 52 / Tarratine Club Rd	4	4	F			X				CMP shorten service taps 12". No tel make ready required. Guying required.			X		*		

Location		Pole #	Attach		Ownership						Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.								
				Tel	El	Tel	El	Tel	El							
Rte 521 / off Tarratine Club Rd	1	4.01	F													*
Rte 522 / off Tarratine Club Rd	2	4.2	F													*
Rte 52 / Tarratine Club Rd	3	4.3	F									X	X		19A,19B,21A	*
Rte 52 / East Shore Dr	5	1	F													*
Rte 52 / East Shore Dr	6	2	F													*
Rte 52 / East Shore Dr	7	3	F										X		10A,11A	*
Rte 52 / East Shore Dr	8	4	F													*
Rte 52 / East Shore Dr	8	4	F													*
Rte 52 / East Shore Dr	9	4H	F													*
Rte 52 / East Shore Dr	10	5	F													*
Rte 52 / East Shore Dr	11	5H	F													*
Rte 52 / East Shore Dr	11	5H	F													*
Rte 52 / East Shore Dr	12	6	F									X	X		7A,11A,25A	*
Rte 52 / East Shore Dr	13	7	F													*
Rte 52 / East Shore Dr	13	7	F													*
Rte 52 / East Shore Dr	14	8	F													*
Rte 52 / East Shore Dr	15	9														*
Rte 52 / East Shore Dr	16	13	F													*
Rte 52 / East Shore Dr	17	15	F										X			*
Rte 52 / East Shore Dr	17-1	15.1	F										X			*

Location		Pole #		Attach		Ownership						Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.		Description of Work	FP	Others	Tasks	Attach location see notes			
				Tel	El	Tel	El	Tel	El								
Rte 52 / East Shore Dr	17-2	15.2	F				X			No make ready required.						*	
Rte 52 / East Shore Dr	NT	16	F						X	No tel on pole. CMP only. No make ready required.						*	
Rte 52 / East Shore Dr	NT	17	F						X	No tel on pole. CMP only. No make ready required. Guying required.						*	
Rte 52 / East Shore Dr	NT	18	F						X	No tel on pole. CMP only. No make ready required. Guying required.						*	
Rte 9225 / East Shore Dr	5	706	F				X			Tel lower 1 d/w 6". Guying required.	X		19A			*	
Rte 9225 / East Shore Dr	5-1	706.1	F				X			No make ready required. Guying required.						*	
Rte 9225 / East Shore Dr	4	705	F				X			CMP cover URD w/12" U-guard. No tel make ready required.		X				*	
Rte 9225 / East Shore Dr	NT	705.1								CMP transformer pad						*	
Rte 9225 / East Shore Dr	3	704	F				X			Tel lower 1 strand(1 ca) 6" .	X		11A			*	
Rte 9225 / East Shore Dr	3-1	704.1	F				X			CMP raise service 12" & shorten taps. Tel lower 1 d/w 12" . Guying required.	X	X	19A			*	
Rte 9225 / East Shore Dr	2	703	F				X			No make ready required. Guying required.						*	
Rte 9225 / East Shore Dr	2D	703.1	F				X			Tel lower 1 d/w 12" . Guying required.	X		19A			*	
Rte 9225 / East Shore Dr	1	702	F				X			No make ready required. Guying required.						*	
Rte 922 / East Shore Dr	4 1/2	701	F				X			No make ready required. Guying required.						*	
Rte 922 / East Shore Dr	4 1/2-1	701.1	F				X			No make ready required. Guying required.						*	
Rte 922 / East Shore Dr off P.4 1/2	5	801	F				X			No make ready required.						*	
Rte 922 / East Shore Dr	6	802	F				X			No make ready required.						*	
Rte 922 / East Shore Dr	6-1	802.1	F				X			Tel lower 1 d/w 12" . Guying required.	X		19A			*	
Rte 922 / Merrill Farm Rd	4	4	F				X			No make ready required.						*	
Rte 922 / Merrill Farm Rd	3	3	F				X			No make ready required.						*	

Location		Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.										
				Tel	El	Tel	El	Tel	El	Tel	El							
Rte 922 / Merrill Farm Rd	3-1	3.1	F					X				No make ready required.				*		
Rte 922 / Merrill Farm Rd	2	2	F					X				Tel lower 1 strand(1 ca) 12"	X		11A	*		
Rte 922 / Merrill Farm Rd off Rte 4 P.74 Pendleton Pt Rd	1	1	F					X				No make ready required. Guying required.				*		
Rte 922 / Merrill Farm Rd	1-1	1.1	F					X				Tel lower 1 d/w, 1 wire term 12"	X		19A,21A	*		
Rte 922 / Merrill Farm Rd	1-2	1.2	F					X				Tel lower 1 d/w 12"	X		19A	*		
Rte 49 / Hatch Ln off Pendleton Pt Rd Rte 4 P.69	1	501	F					X				No make ready required.				*		
Rte 49 / Hatch Ln	2	502	F					X				CMP raise service 24" & shorten taps. No tel make ready required. Guying required.		X		*		
Rte 49 / Hatch Ln	2 1/2	502H	F					X				No make ready required.				*		
Rte 49 / Hatch Ln	3	503	F					X				No make ready required.				*		
Rte 49 / Hatch Ln	4	504	F					X				No make ready required.				*		
Rte 49 / East Shore Road	5	505	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	5-1	505.1	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	6	506	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	7	507	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	8	508	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	9	509	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	10	510	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	11	511	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	12	512	F					X				No make ready required. Guying required.				*		
Rte 49 / East Shore Road	13	513	F					X				CMP raise neutral 6". No tel make ready required. Guying required.		X		*		

Location			Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.	J.U.	S.O.	J.O.			J.U.			S.O.						
				Tel	El		Tel	El		Tel	El	Tel	El						
Rte 49 / East Shore Road	14	514	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	15	515	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	15-1	515.1	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	15-2	515.2	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	16	516	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	17	517	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	17-1	517.1	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	17-2	517.2	F								X			CMP shorten service taps 18". No tel make ready required. Guying required.			*		
Rte 49 / East Shore Road	17 1/2	517H	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	18	518	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	19	519	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	19	519	F								X			DDE(double deadend) second attachment.			*		
Rte 49 / East Shore Road	20	520	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	21	521	F								X			No make ready required. Guying required.			*		
Rte 49 / East Shore Road	21	521	F								X			DDE(double deadend) second attachment.			*		
Rte 49 / East Shore Road	22	522	F								X			Tel lower top d/w 12". Guying required.	X	19A	*		
Rte 49 / Boardman Rd	22-1	522.1	F								X			Tel lower 1 crw, 2 d/w, 1 wire term 12". Guying required.	X	20A,(2)19B,21A	*		
Rte 49 / Boardman Rd	22-2	522.2	F								X			Tel lower 1 d/w 12". Guying required.	X	19A	*		
Rte 49 / Boardman Rd	23	523	F								X			No make ready required. Guying required.			*		
Rte 49 / Boardman Rd	24	524	F								X			No make ready required. Guying required.			*		

Location			Pole #	Attach	Ownership						Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.	J.U.	S.O.									
				Tel	El	Tel	El	Tel	El						
Rte 49 / Boardman Rd	25	525	F					X				No make ready required. Guying required.			*
Rte 49 / Boardman Rd	26	526	F					X				No make ready required. Guying required.			*
Rte 49 / Boardman Rd	26	526	F					X				DDE(double deadend) second attachment.			*
Rte 49 / Boardman Rd	27	527	F					X				No make ready required. Guying required.			*
Rte 49 / Boardman Rd	28-1	528	F					X				No make ready required. Guying required.			*
Rte 49 / Boardman Rd	NT	528.3										CMP transformer pad			*
Rte 49 / Boardman Rd	28	529	F					X			X	Tel lower top d/w 12". Guying required.		19A	*
Rte 49 / Boardman Rd	NT	529.1										Customer owned meter pole.			*
Rte 4 / Pendleton Point Rd	107	369	F					X				No make ready required.			*
RP51 / Gilkey Ln off P.107	1	1	F					X				No make ready required.			*
RP51 / Gilkey Ln	2	2	F					X				No make ready required.			*
RP51 / Gilkey Ln	3	3	F					X			X	Tel lower top d/w 12". Guying required.		19A	*
RP51 / Gilkey Ln	4	4	F					X				No make ready required.			*
Rte 4 / Pendleton Point Rd	106	368	F					X				No make ready required. Guying required.			*
Rte 4 / Pendleton Point Rd	105	367	F					X				No make ready required.			*
Rte 4 / Decker Rd off Pendleton Point Rd	105D	1	F					X				No make ready required.			*
Rte 4 / Pendleton Point Rd	104	366	F					X				No make ready required. Guying required.			*
Rte 4 / Pendleton Point Rd	104-1	366.1	F					X			X	Tel lower 1 d/w 12".		19A	*
Rte 4 / Pendleton Point Rd	103	365	F					X				No make ready required.			*
Rte 4 / Pendleton Point Rd	102	364	F					X				No make ready required.			*

Location			Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.											
				Tel	El	Tel	El	Tel	El	Tel	El								
Rte 4 / Pendleton Point Rd	101	363	F						X				No make ready required.				*		
Rte 4 / Pendleton Point Rd	100	363	F						X				Tel lower 2 strands(4 ca), 1 d/w, 1 PA guy 12".	X		10A,11A,11B,19A	*		
Rte 48 / Babbidge Rd off Pendleton Pt Rd P.100	1	1	F						X				Tel raise 1 strand(1 ca), 2 d/w, 1 PA guy 12". Guying required.	X		10A,11A,19A,19B	*		
Rte 48 / Babbidge Rd	2	2	F						X				CMP rpl 35'/40'. Tel transfer 2 strands(2 ca). NO CHARGE. Noncompliant clearance, Tel 18" to CMP service, 17' over road.	X	X		*		
Rte 48 / Babbidge Rd	2S	2S							X				No make ready required. Guying required.				*		
Rte 485 / Colony Road off Rte 48 P.2	1	2.1	F						X				No make ready required. Guying required.				*		
Rte 485 / Colony Road	1-1	2.11	F						X				Tel lower 1 d/w 12".	X		19A	*		
Rte 485 / Colony Road	2	2.2	F						X				No make ready required.				*		
Rte 485 / Colony Road	NT	2.21	F								X		No tel on pole. CMP only. No make ready required.				*		
Rte 485 / Colony Road	3	2.3	F						X				No make ready required. Guying required.				*		
Rte 485 / Colony Road	4	2.4	F						X				No make ready required.				*		
Rte 48 / Babbidge Rd	3	3	F						X				No make ready required.				*		
Rte 48 / Babbidge Rd	4	4	F						X				No make ready required.				*		
Rte 48 / Babbidge Rd	5	5	F						X				No make ready required.				*		
Rte 48 / Babbidge Rd	6	6	F						X				No make ready required. Guying required.				*		
Rte 48 / Babbidge Rd	6S	6S	F						X				No make ready required. Guying required.				*		
RP59 / Colony Rd off Rte 48 P.6	1	1	F						X				CMP cover URD w/24" U-guard & shorten service taps. No tel make ready required.		X		*		
RP59 / Colony Rd	2	2	F						X				No make ready required. Guying required.				*		
Rte 48 / Babbidge Rd	7	7	F						X				Tel lower 1 strand(1 ca) 12".	X		11A	*		

Location			Pole #	Attach	Ownership										Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.											
				Tel	El	Tel	El	Tel	El										
Rte 48 / Babbidge Rd	8	8	F					X			No make ready required. Guying required.					*			
Rte 47 / West Shore Rd	NT	34	F							X	No tel on pole. CMP only. No make ready required. Guying required.					*			
Rte 47 / West Shore Rd	33	33	F					X			No make ready required. Guying required.					*			
Rte 47 / West Shore Rd	33-1	33.1	F					X			No make ready required.					*			
Rte 475 / Babbidge Rd off West Shore Rd P.33	1	1	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	2	2	F					X			No make ready required.					*			
Rte 475 / Babbidge Rd	3	3	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	4	4	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	5	5	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	6	6	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	7	7	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	8	8	F					X			No make ready required. Guying required.					*			
Rte 475 / Babbidge Rd	8-1	8.1	F					X			Tel lower 1 d/w 12".	X		19A		*			
Rte 475 / Babbidge Rd	NT	9									CMP transformer pad								
Rte 475 / Babbidge Rd	NT	10									CMP transformer pad								
Rte 475 / Babbidge Rd	NT	10.1									CMP transformer pad								
Rte 475 / Babbidge Rd	NT	11									CMP transformer pad								
Rte 47 / West Shore Rd	32	32	F					X			No make ready required. Guying required.					*			
Rte 47 / West Shore Rd	31	31	F					X			No make ready required. Guying required.					*			
Rte 47 / West Shore Rd	30	30	F					X			No make ready required. Guying required.					*			

Location		Pole #		Attach		Ownership				Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.							
				Tel	El	Tel	El	Tel	El						
Rte 47 / West Shore Rd	30-1	30.1	F				X			No make ready required.					*
Rte 47 / West Shore Rd	29	29	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	28	28	F				X			No make ready required.					*
Rte 47 / West Shore Rd	27	27	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	27D	27.1	F				X			No make ready required.					*
Rte 47 / West Shore Rd	26	26	F				X			No make ready required.					*
Rte 47 / West Shore Rd	25	25	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	24S	24.1	F				X			CMP raise service 18" & pull slack. No tel make ready required.		X			*
Rte 47 / West Shore Rd	24-1	24.2	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	23	23	F				X			No make ready required.					*
Rte 47 / West Shore Rd	22	22	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	22-1	22.1	F				X			No make ready required. Guying required.					*
Rte 47 / West Shore Rd	NT	22.2								CMP transformer pad					*
Rte 47 / West Shore Rd	22S	22S	F				X			Tel lower 1 PP guy, 1 PA guy 12". Guying required.	X		10A,10B		*
Rte 47 / West Shore Rd	21	21	F				X			Raise 2 strands(2 ca), 1 mdw 12", 1 term, rpl 1 PA guy	X		7A,11A,11B,14A,19A,25A		*
Rte 47 / West Shore Rd	21-1	21.1	F				X			Tel lower 1 strand(1 ca), 1 mdw, 1 PA guy 12"	X		10A,11A,19A		*
Rte 47 / West Shore Rd	20	20	F				X			No make ready required.					*
Rte 47 / West Shore Rd	19	19	F				X			CMP shorten service taps 12". No tel make ready required.		X			*
Rte 47 / West Shore Rd	19D	19.1	F				X			Tel lower 3 d/w 12".	X		19A,(2)19B		*
Rte 47 / West Shore Rd	19D1	19.2	F				X			Tel lower 3 d/w 12".	X		19A,(2)19B		*

Location			Pole #	Attach	Ownership								Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.									
				Tel	El	Tel	El	Tel	El	Tel	El						
Rte 47 / West Shore Rd	18	18	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	18S	18S						X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	17	17	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	16	16	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	NT	16.1	F							X		No tel on pole. CMP only. No make ready required.				*	
Rte 47 / West Shore Rd	15	15	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	14	14	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	14-1	14.1	F					X				No make ready required.				*	
Rte 47 / West Shore Rd	NT	14.01	F							X		No tel on pole. CMP only. No make ready required.				*	
Rte 47 / West Shore Rd	13	13	F					X				No make ready required.				*	
Rte 47 / West Shore Rd	13D	13.1	F					X				No make ready required.				*	
Rte 47 / West Shore Rd	12 1/2	12H	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	NT	12HS								X		No tel on pole. CMP only. No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	12	12	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	11	11	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	10	10	F					X				Tel lower 1 mdw 24".	X		19A	*	
Rte 47 / West Shore Rd	10-1	10.1	F					X				CMP rpl 30'/40'. Tel transfer 1 mdw, 1 wire term, 1 bsw. NO CHARGE. Noncompliant clearance, Tel 12" from secondary, 17' 5" over road.	X	X		*	
Rte 47 / West Shore Rd	9	9	F					X				No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	9S	9S						X				No make ready required. Guying required.				*	

Location			Pole #		Attach		Ownership						Description of Work	FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	J.O.		J.U.		S.O.									
				Tel	El	Tel	El	Tel	El	Tel	El						
Rte 47 / West Shore Rd	8	8	F				X					No make ready required. Guying required.				*	
Rte 47 / West Shore Rd	7	7	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive off Rte 47 P.7	1	1	F				X					No make ready required.				*	
Rte 473 / Long Ledge Drive	2	2	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive	3	3	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive	4	4	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive	4-1	4.1	F				X					CMP pull slack secondary P.4 to 4.1. No tel make ready required.	X			*	
Rte 473 / Long Ledge Drive	4-11	4.11	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive	4-01	4.01	F				X					No make ready required.				*	
Rte 473 / Long Ledge Drive	4-2	4.2	F				X					No make ready required.				*	
Rte 473 / Long Ledge Drive	4-3	4.3	F				X					No make ready required. Guying required.				*	
Rte 473 / Long Ledge Drive	5	5	F				X					CMP raise service 12" & shorten taps. No tel make ready required. Guying required.	X			*	
Rte 473 / Long Ledge Drive	5 1/2	5H	F				X					CMP raise service 12" & shorten taps. Tel lower 1 mdw 6". Guying required.	X	X	19A	*	
Rte 473 / Long Ledge Drive	6	6	F				X					CMP rpl 35'/40'. Tel transfer 1 strand(1 ca),1 mdw, rpl 1PA guy.	X	X	7A,11A,17A,25A	*	
Totals				0	0	0	0	190	0	8			34	18			

Notes:

* Attach no closer than 40" below power attachment and 12" above telephone attachment.