

Date: 01/08/2016

TOWN OF ISLESBORO  
P.O BOX 76  
ISLESBORO, Maine 04848

RE: Application number A-2015-1527  
Licensee reference number: ISLESBORO10

Dear CRISTIN TURNER:

Enclosed you will find the field survey results for the above application in the vicinity of EMERY RD,, Islesboro, ME. While there is Make-Ready Work required in order for you to be licensed to attach to these poles, you will not be billed.

We will notify you of the Estimated Construction Completion Date(ECCD) and keep you informed of any delays.

Please call 1-866-774-5228 to speak with a License Administration Associate should you have any questions.

Sincerely,

Cathleen Adams  
License Administration

Attachments

# FORM 3 - FAIRPOINT ITEMIZED POLE MAKE-READY WORK CHARGES

Appendix IV Form 3

FIELD SURVEY / MAKE READY WORK FORM																									
RCE to Complete - Total Poles Surveyed					22					Total Poles Requiring Make Ready					Fairpoint 2 Others 2										
Surveyors:					Survey Date: 01/07/16					Survey Order # MEA20151527APP															
Fairpoint Bill Redman					Munic: Islesboro State: Maine					Exch Code: 7283 Munic Code: 7283901															
Licensee					Licensee Name: Town of Islesboro					License Application # Islesboro 10															
Elco Elmer Plummer					Elco Name: Central Maine Power					LAG Application # A-2015-1527					days										
Location		Pole #		Attach		Ownership		F/C		J.O.		J.U.		S.O.		Description of Work		FP		Others		Tasks		Attach location see notes	
Tel	Rte / Street Name	El	PS	Tel	El	Tel	El	Tel	El	Tel	El	Tel	El	Tel	El										
18	Rte 70 / Emery Rd, Seven Hundred Acre Island	18	F									X				No make ready required. Guying required.								*	
18-1	Rte 70 / Emery Rd, Seven Hundred Acre Island	18.1	F									X				CMP transfer URD & aerial service to new pole & extend URD w/ U-guard. Tel transfer 4 d/w, 1 PA guy to new pole. NO CHARGE. Work on another authority.	X	X					*		
NT	Rte 70 / Emery Rd, Seven Hundred Acre Island	19H														No pole or pad found							*		
19	Rte 70 / Emery Rd, Seven Hundred Acre Island	19	F									X				No make ready required. Guying required.							*		
19	Rte 70 / Emery Rd, Seven Hundred Acre Island	19	F									X				DDE( double deadend) second attachment							*		
20	Rte 70 / Emery Rd, Seven Hundred Acre Island	20	F									X				No make ready required. Guying required.							*		
21	Rte 70 / Emery Rd, Seven Hundred Acre Island	21	F									X				No make ready required. Guying required.							*		
22	Rte 70 / Emery Rd, Seven Hundred Acre Island	22	F									X				No make ready required.							*		
23	Rte 70 / Emery Rd, Seven Hundred Acre Island	23	F									X				No make ready required.							*		
23 1/2	Rte 70 / Emery Rd, Seven Hundred Acre Island	23H	F									X				No make ready required.							*		
24	Rte 70 / Emery Rd, Seven Hundred Acre Island	24	F									X				No make ready required.							*		
25	Rte 70 / Emery Rd, Seven Hundred Acre Island	25	F									X				CMP rpl 35'/40'. New pole at site, not set. Tel transfer 1 strand(1 ca), 1 term, 2 mdw, rpl 1 PA guy. NO CHARGE. Noncompliant clearance. Tel 36" from Neutral, 11'9" over driveway.	X	X					*		

Location		Pole #	Attach	Ownership								Description of Work		FP	Others	Tasks	Attach location see notes
Tel Rte / Street Name	Tel	El	F/C PS	I.O.		I.U.		S.O.									
				Tel	El	Tel	El	Tel	El								
Rte 70 / Emery Rd, Seven Hundred Acre Island	25-1	25.1	F				X					No make ready required.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	25-2	25.2	F				X					No make ready required.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	25-3	25.3	F				X					No make ready required. Guying required.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	26	26	F				X					No make ready required.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	NT	26.1										CMP transformer pad				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	27	P27	F									Private pole				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	28	P28	F									Private pole. Tree on power.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	29	P29	F									Private pole. Tree on power.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	30	P30	F									Private pole				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	31	P31	F									Private pole				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	32	P32	F									Private pole. Power wires down, top of pole broken.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	33	P33	F									Private pole. Power wires down.				*	
Rte 70 / Emery Rd, Seven Hundred Acre Island	34	P34	F									Private pole. Power wires down, top of pole broken.				*	
Totals				0	0	0	0	15	0	0			2	2			

Notes:

\* Attach no closer than 40" below power attachment and 12" above telephone attachment.